

**BLOCK WATER TESTING LABORATORY, BATALA**

Judicial Court Complex on Police line Road, Opposite Police Station, Batala.  
bwtlbt@gmail.com

To,

Millennium Public School  
Millennium Public School, Naushera Majha Singh

No.: BWTLBTL/2425/00143      Dated : 18/02/2025

Subject :            Testing Reports of Water Samples.

Reference:        Your Letter/SRF No. 256    Dated: 07/02/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 07/02/2025. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Batala

D/A :                Test Report



**Authorized Signatory  
For, Block Water Testing Laboratory  
Batala**

# BLOCK WATER TESTING LABORATORY, BATALA

Judicial Court Complex on Police line Road, Opposite Police Station, Batala.

bwtlbt@gmail.com

TEST REPORT						
Name & Address of Customer : <b>Millennium Public School</b> <b>Millennium Public School, Naushera Majha Singh</b>			Customer Reference No.		No : 256 Dated : 07/02/2025	
			Sample Submitted by		Preet Ghuman	
			Date of Sample Receipt		07/02/2025	
			Analysis Starting Date		17/02/2025	
			Analysis completion Date		18/02/2025	
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:		NABLDWT0026025017F		Sample Type :		Water
Test Report No.:		BWTLBTL/2425/00143		Date of Issue :		18/02/2025
Registration no.:		BWTLBTL/REG2425/00239		Condition of Sample :		Sealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		NA / 400 ft
Village :		N.M.Singh		Habitation :		N.M.Singh
Block:		Dhariwal		District :		Gurdaspur
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.71	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	110	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.50	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO <sub>3</sub> )	108	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO <sub>3</sub> )	88	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	27.25	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	4.86	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	17.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



**Mr. Pankaj Kumar**  
Quality Manager  
Authorized Signatory  
For,Block Water Testing Laboratory  
Batala

----- End of the Test Report -----